

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:51 pm

PWS ID: UTAH25022 **Name:** PLEASANT GROVE CITY
Legal Contact: PLEASANT GROVE CITY **Rating:** Approved
GREGORY H WOODCOX **Rating Date:** 03/11/1980
Address: 70 S 100 E **Activity Status:** Active
PLEASANT GROVE, UT 84062
Phone Number:
City Served (Area):
County: UTAH COUNTY
System Type: Community **Last Inv Update:** 07/19/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/05/2006 **Total Dsgn Cap:**
Population: 27,400 **Surveyor:** JOHN H OAKESON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	WOODCOX, GREGORY H		801-785-2941	801-420-0581	gwoodcox@pgcity.org

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	6,050
			6,050 Total Svc Connections

Storage

Total Storage: 11,000,000 G³ **Number of Units:** 7 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST006	MANILA TANK	Ground	5,000,000 GAL	Concrete		A	NO
ST007	MONSON #3	Ground	150,000	Concrete		A	NO
ST001	BATTLECREEK #1	Ground	1,500,000 GAL	Steel		A	NO
ST002	MONSON #1	Ground	2,000,000 GAL	Concrete		A	NO
ST003	MONSON #2	Ground	100,000 GAL	Concrete		A	NO
ST004	GROVE CREEK STORAGE	Ground	2,000,000 GAL	Concrete		A	NO
ST005	BATTLECREEK #2	Ground	250,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	BATTLE CREEK SPRING CHLORINATOR		A	
TP002	WADE SPRING CHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	BATTLE CREEK PUMP STATION #	A		P			
PF002	BATTLE CREEK PUMP STATION #	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	BATTLE CREEK SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	WADE SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	BLUE CREEK SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS004	LOST SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS005	HANGMANS SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS006	BRIMLEY WELL	Active	WL	16	2200 GPM	2,200 GPM	Yes	GW	Seasonal		
WS007	MONSON WELL	Active	WL	16	1200 GPM	1,300 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS008	BATTLE CREEK WELL	Active	WL	16	1000 GPM	1,750 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS009	GROVE CREEK WELL	Active	WL	16	600 GPM	620 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS010	ANDERSON PARK WELL	Active	WL	16	1346 GPM	1,500 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS011	CEMETERY WELL	Inactive	WL	16	1250 GPM		Yes	GW	Other		
WS012	EKINS WELL	Active	WL	16	850 GPM	435 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS013	GIBSON WELL	Active	WL		3000 GPM	3,000 GPM	Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*